

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No.....

Dated: 12/03/26

It is certified that an inspection team headed by Dr. Arun (Name of Officers with designation) from C.H.C. Gulaothi inspected the **Shivam Public School, Kazampur Devli, Gulaothi Road, Bulandshahr (U.P.)** (Name & Address of the school) on 11/03/26 (date of inspection) and on the basis of Water Test Report (Attached) bearing no **T9249** dated **12-03-2026** of **District Level Water Analysis Laboratory UP Jal Nigam (Rural), Bulandshahr** (PHED Lab) certified that the **Shivam Public School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

**This certificate is valid till One Year**

Signature with Seal:

Name : Dr. ArunDesignation : M.O.

Name &amp; Address of the Office / Department:

**C.H.C. GULAOTHI  
(Bulandshahr)**

To,  
Shivam Public School  
Kazampur Devli, Gulaothi Road, Bulandshahr (U.P.)  
(Name & Address of the Institution)

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.**




# District Level Water Analysis Laboratory UP Jal Nigam (Rural), Bulandshahr

## TEST REPORT

UTR NO:	: T 9249	Issue Date	12/03/2026	
Sample receipt Date:	: 11/03/2026	Expired Date	11/09/2026	
Customer/Party Name	: SHIVAM PUBLIC SCHOOL			
Address	: KAZAMPUR DEVL, GULAOTHI ROAD BULANDSHAHR			
Contact No.	: 9412512899			
Date of Sampling	: 11/03/2026	Sample Code: B 162		
Sample Description	: 11/03/2026	Quantity of Sample	1000ML	
Quantity	: 1	Water Source	SAMARSAVEL WATER	
Packing details	:	Sampling Method	As per IS 17614:Part-2021	
Analysis Start	: 11/03/2026	Analysis Completion Date	12/03/2026	
Temperature	: 26.8°C	Humidity	54%	
Water Sample Provided By .....Abneesh Kumar				
Availability of Equipments:		Availability of reference standards:	Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:	Duration of testing/Time of Report release	12:30 pm

## TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.392	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	2.874	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	408.6	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	156	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	216	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	200	(Mg/L)*
7	Colour	APHA 23 <sup>rd</sup> Edistion	5	15	6	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part ): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca	-	75	200	80	(Mg/L)
11	Magnesium as	-	30	100	50.36	(Mg/L)
Remark	"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."					

6.A.   
Reviewed By

Pass (  )  
Fail (  )

End of Report

